

- (d) Local Limits The following pollutant limits are established to protect against pass through and interference. No person shall discharge wastewater containing in excess of the following instantaneous maximum allowable discharge limits:

<u>Parameter</u>	<u>Limit</u>
Arsenic (As)	1.0 mg/l
Cadmium (Cd)	0.6 mg/l
Chromium (Cr)	8.0 mg/l
Copper (Cu)	1.9 mg/l
Cyanide (CN)	1.2 mg/l
Lead (Pb)	0.8 mg/l
Mercury (Hg)	0.0003 mg/l
Nickel (Ni)	7.0 mg/l
Silver (Ag)	1.9 mg/l
Zinc (Zn)	3.4 mg/l
Phosphorus (P)	23.4 mg/l
Oil & Grease	250 mg/l
pH	5.0/12.0

The above limits apply at the point where the wastewater is discharged to the POTW.

All concentrations for metallic substances are for "total" metal unless indicated otherwise.

The Superintendent may impose mass limitations in addition to, or in place of, the concentration-based limitations above.

(Ord. 85-1993 §2. Passed 11-3-93; Ord. 32-1996 §1. Passed 5-22-96; Ord.61-1999. Passed 10-13-99; Ord. 25 – 2016, Passed 8-3-2016).